

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Connector, rewirable

Name and address of the applicant

Neutrik AG
Im alten Riet 143, 9494 SCHAAN
LIECHTENSTEIN

Name and address of the manufacturer

Neutrik AG
Im alten Riet 143, 9494 SCHAAN
LIECHTENSTEIN

Name and address of the factory

Neutrik Hungary Kft.
Pap ut 4, 3600 Ozd
HUNGARY

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Additional Information on page 2
AC 250 V, 16 A,
Non-standardized construction
Suitable for use at altitudes up to 4000 m

Trademark (if any)

NEUTRIK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NAC3F-TRUE1-S,
NAC3F-TRUE1-L

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60320-1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

311541-TL3-9

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierungsstelle und internat. Angelegenheiten
Certification Body and internat. Affairs

Date: 2024-01-19

Signature:



A. Fabian